



CONTRACT WASTE HAULING PROGRAM

WASTE ACCEPTANCE CRITERIA

MAXIMUM CONCENTRATION OF SLUDGE CONSTITUENTS ALLOWABLE (1)

<u>Parameter</u>	<u>Concentration</u> (Dry Weight Basis)
Cadmium, Total	39 (mg/kg)
Chromium, Total	1200
Copper, Total	1500
Lead, Total	300
Mercury, Total	17
Nickel, Total	420
Zinc, Total	2500 (2)

GENERAL LIMITATIONS

pH	5-10 Std. Units (3)
TVS	55% Minimum (4)
Oil/Grease	100 mg/L (3)
Ammonia Nitrogen	500 mg/L (3)

PROHIBITED DISCHARGES

Grease Trap Waste.

Medical, Infectious or Biohazard Waste.

Priority Pollutant Waste.

Characteristic or Listed Hazardous Waste.

Digester, Lagoon or Tank Cleaning.....waste, grit or mat.



Notes

- (1) Annual and Lifetime Sewage Sludge Application Rates for Agricultural Utilization, 25 Pa. Code, Section 275.201 (b)(3).
- (2) Capital Region Water AWTF Standard.
- (3) Variances will be granted on a case-by-case basis.
- (4) Applicable to process waste haulers only.